



#### NOTES

1. STEPS IRONS REQUIRED WHEN DIMENSION 'D' EXCEEDS 1.5M
2. BENCHING TO JUNCTION BOXES ONLY.
3. WHERE BENCHING IS USED INVERT TO INLET OF JUNCTION BOX TO BE SET 25mm MINIMUM ABOVE OUTLET INVERT LEVEL.
4. WHERE PHYSICAL ACCESS IS REQUIRED JUNCTION BOX DIMENSIONS 'A' AND 'B' TO BE 1200 x 1200.

### SECTION X-X

DRAWN	N. LANGLEY S. HYDE	TOWN OF GAWLER	SCALE N.T.S.
CHECKED	D. COLLINS	STANDARD DETAILS	DRAWING NUMBER
DATE	JUNE 2011	JUNCTION BOX/ GRATED INLET PIT	SK - 100